



# भारत का राजपत्र The Gazette of India

असाधारण

EXTRAORDINARY

भाग II—खण्ड 3—उप-खण्ड (ii)

PART II—Section 3—Sub-section (ii)

प्राधिकार से प्रकाशित

PUBLISHED BY AUTHORITY

सं. 2337]

नई दिल्ली, शुक्रवार, नवम्बर 14, 2014/कार्तिक 23, 1936

No. 2337]

NEW DELHI, FRIDAY, NOVEMBER 14, 2014/KARTIKA 23, 1936

## भारी उद्योग और लोक उद्यम मंत्रालय

## आदेश

नई दिल्ली, 14 नवम्बर, 2014

का.आ. 2917(अ).—केन्द्रीय सरकार, भारतीय मानक ब्यूरो अधिनियम, 1986 (1986 का 63) की धारा 14 द्वारा प्रदत्त शक्तियों का प्रयोग करते हुए, भारतीय मानक ब्यूरो से परामर्श करने के पश्चात् विद्युत ट्रांसफॉर्मर (गुणवत्ता नियन्त्रण) आदेश, 2014 में संशोधन करने के लिए निम्नलिखित आदेश करती है, अर्थात्:—

- (1) इस आदेश का संक्षिप्त नाम विद्युत ट्रांसफॉर्मर (गुणवत्ता नियन्त्रण) संशोधन आदेश, 2014 है।
- (2) यह 01 फरवरी, 2015 को प्रवृत्त होगा।

- विद्युत ट्रांसफॉर्मर (गुणवत्ता नियन्त्रण) आदेश, 2014 —

(i) पैराग्राफ 2, खंड (ड), में शब्द "या मरम्मत" का लोप किया जाएगा;

(ii) अनुसूची के स्थान पर निम्नलिखित अनुसूची रखी जाएगी, अर्थात्

## अनुसूची

[कृपया पैरा 2 (च) देखें]

भारतीय मानक ब्यूरो के आज्ञापक प्रमाणन के अधीन इलेक्ट्रिकल ट्रांसफार्मरों की सूची

क्र.सं.	भारतीय मानक संख्या (नवीनतम वर्जन)	शीर्षक	आईटीसी (एच एस) कोड
		बाह्य प्रकार के तेल में डूबे हुए वितरण ट्रांसफॉर्मर्स तक और 2500 केवीए, 33 केवी सहित - विनिर्दिष्टियाँ भाग 1 खनिज तेल में डूबे हुए	
1	भा.मा. 1180 (भाग-1): 2014	(क) गैर-मुहर बंद और मुहर बंद, दोनों प्रकार के 200 केवीए सहित और इस क्षमता तक तीन-चरण रेटिंग। (ख) गैर-मुहर बंद और मुहर बंद, दोनों प्रकार के 200 केवीए से अधिक क्षमता तक और 2500 केवीए सहित तीन-चरण रेटिंग। (ग) मुहर बंद प्रकार के 25 केवीए सहित और इस क्षमता तक सिंगल-फेस रेटिंग।	85043100 85043200 85043300 85043400

[फा. सं. 5(2)/2009-पीई-XI (खंड II)]

अंबुज शर्मा, अपर सचिव

पाद टिप्पण :—मूल आदेश का. आ. संख्यांक 266(अ) तारीख 27 जनवरी, 2014 द्वारा प्रकाशित किया गया था।

## MINISTRY OF HEAVY INDUSTRIES AND PUBLIC ENTERPRISES

## ORDER

New Delhi, the 14th November, 2014

**S.O. 2917(E).**— In exercise of the powers conferred by section 14 of the Bureau of Indian Standards Act, 1986 (63 of 1986), the Central Government, after consulting the Bureau of Indian Standards, hereby makes the following Order to amend the Electrical Transformers (Quality Control) Order, 2014, namely :--

1. (1) This Order may be called the Electrical Transformers (Quality Control) Amendment Order, 2014.

(2) It shall come into force on the 1<sup>st</sup> day of February, 2015.

2. In the Electrical Transformers (Quality Control) Order, 2014,—

(i) in paragraph 2, clause (e), the words “or repairs” shall be omitted;

(ii) for the Schedule, the following Schedule shall be substituted, namely:—

**SCHEDULE**

[See paragraph 2(f)]

List of Electrical Transformers under mandatory Bureau of Indian Standards certification

Sl. No.	Indian Standard number (Latest version)	Title	ITC (HS) Code
		Outdoor type oil immersed Distribution Transformers upto and including 2500 KVA, 33KV- specification Part 1 Mineral oil immersed	
1.	<b>IS 1180(Part 1):2014</b>	(a) Three-phase ratings upto and including 200 KVA both Non-sealed type and sealed type.	85043100
		(b) Three phase ratings higher than 200 KVA upto and including 2500 KVA both non-sealed type and sealed type.	85043200
		(c) Single phase ratings upto and including 25 KVA sealed type.	85043300 85043400

[F.No.5(2)/2009-PE.XI (Vol.II)]  
AMBUJ SHARMA, Addl. Secy.

**Footnote:**—The principal Order was published vide number S.O. 266(E), dated the 27th January, 2014.